

Certificate of Compliance

Certificate Number **042303-E206284**
Report Reference **E206284, April 23, 2003**
Issue Date **2007 February 5**

Page 1 of 1



Issued to: **EnviroGuard**
5534 OLIVE ST
Montclair, CA 91763

This is to certify that representative samples of

Spill Containment for Stationary Lead-Acid Battery
Spill containment systems, Model Eagle#, Condor Plus#, Hawk#.

- May have alphanumeric suffix to describe overall containment area.


Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

In accordance with ASTM E648-99 - Standard Test Method for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source; UL 2436 - Outline of Investigation for Spill Containment for Stationary Lead-Acid Battery System, 1st Ed.

Additional Information:

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by: *Joel P. Acierto*

Joel P. Acierto, Associate Project Engineer

Underwriters Laboratories Inc.

Reviewed by: *Laurie B. Florence*

Laurie B. Florence, Primary Designated Engineer

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions in The United States of America you may call 1-877-UL-HELPS.